

# BOILER ENGINEERING "CHEAT SHEET"

## VOLUME

1 ltr = 0.2642 gal     $m^3 \times 35.31 = ft^3$

## TEMPERATURE

$F^\circ \times 1.8 + 32 = C^\circ$      $C^\circ = (32 + (9/5)^\circ F)$

## PRESSURE

PSI = 14.5 x bars    PSI = 0.001422 x kg/m<sup>2</sup>    PSI = 14.22 x kg/cm<sup>2</sup>    PSI = 14.7 x atm

## HEAT

BTU x 0.252 = Kcal    Kcal x 3.968 = BTU    1 therm = 100,000 BTU    1 gigajoule = 948mBTU

## BOILER ROOM

1BHP (steam from and @ 212°F) = 34.5 lb/hr = 15.65 kg/hr = 33,475 btu/hr = 8435.7 Kcal/hr = 9.803 kw = 0.335 therm = 35.3 GJ

BTU input required (Biomass) @: ~79% efficiency (8% Moisture Content Fuel) = 41,844 BTU or 10,545 Kcal x BHP

~69% efficiency (50% Moisture Content Fuel) = 47,821 BTU or 12,051 Kcal x BHP

## FUEL

natural gas @ 1000 btu/ft<sup>3</sup>

#1 & #2 oil @ 140,000 BTU/gal

#6 oil @ 150,000 BTU/gal

butane @ 102,600 BTU/gal

propane @ 91,500 BTU/gal

coal @ 12,500 BTU/lb

10% MC Pine @ 7,650 BTU/lb

35% MC Pine @ 5,525 BTU/lb

50% MC Pine @ 4,250 BTU/lb

## QUANTITY INPUT / 1 BHP

42 ft<sup>3</sup> / 1.18 m<sup>3</sup>

0.29 gal / 1.09 ltr

0.27 gal / 1.02 ltr

0.40 gal / 1.51 ltr

0.45 gal / 1.70 ltr

3.5 lbs / 1.58 kg

6 lbs / 2.72 kg

9 lbs / 4.08 kg

12 lbs / 5.44 kg

burner(60 Hz) BTU output/0.833=BTU output @ 50 Hz

4% output reduction for each 1,000 FT over 2,000 FT altitude

120 mg/nM<sup>3</sup> @ 8% O<sup>2</sup> = 0.052 gr/dscf @ 12% O<sup>2</sup>

## HEAT EXCHANGERS & HOT WATER BOILERS

1 BTU to raise 1 lb of H<sub>2</sub>O 1° F    example: 78° F H<sub>2</sub>O (in) - 194° F H<sub>2</sub>O (out) = 116° F ΔT, 1 gal of water weighs 8.337 lbs 116° F ΔT x 8.337 = 967.1 BTU input required /gal of water

## HEAT RECOVERY BOILER

Q = M<sub>cp</sub>ΔT    where Q = quantity of BTU's available, M = mass flow gases (lbs), cp = constant specific heat, assume (0.3 BTU/#)

/F<sup>o</sup>, ΔT = temperature differential

## BUILDING HEATING

100 bhp/70,000 FT<sup>2</sup>, Assuming 25' ceilings, 10 F° ΔT outside temperature (50 BTU/FT<sup>2</sup>)    Glycol = +15% heating surface

## LUMBER / WOOD WASTE / DRYING (ESTIMATES)

424 bf = 1 M<sup>3</sup>

**Conventional Kilns** (3 day/72 hour schedule)(3.6 BHP/1000 BF):

1<sup>st</sup> kiln - 125 BTU/BF, 2<sup>nd</sup> kiln +50%, >2 kilns - 87.5 BTU/BF per kiln

**Hi Temp Kilns** (1 day / 24 hour schedule): 1<sup>st</sup> kiln - 225 BTU/BF, 2<sup>nd</sup> kiln - +50%, >2 kilns - 157 BTU/BF per kiln

**Hardwood/Poplar Kilns** (1 month/30 day schedule)(1 BHP/1,000 BF (hardwood)):

15 PS steam ≤2 kilns, 150 PSI steam ≥3 or more kilns (expense offset by lower kiln costs)

1<sup>st</sup> kiln-35 BTU/BF (40 BTU/BF-oak, 50 BTU/BF-poplar, 60 BTU/BF-white maple), 2<sup>nd</sup> kiln-25 BTU/BF (35 BTU/BF-poplar), ≥ 3 kilns-

20 BTU/BF (29 BTU/BF-poplar) per kiln

## BIOMASS FUEL STORAGE CAPACITY

BHP x 48,000 BTU/BHP (or required) ÷ BTU of fuel = lbs/hr ÷ lbs/Ft<sup>3</sup> x time (hrs) = storage volume req.

2.5 x diameter = total silo height (max. recommended for wood waste)

One (1) HBC reciprocating floor "tree" stores ~1,000 FT<sup>3</sup> (truck shipped domestically in 3-tree units, container shipped in 2-tree units)

## ELECTRIC MOTORS

Motor horsepower x 0.746 = KW power consumption

## COGEN

From 270 PSI    Turbine Exhaust @ 0 PSI - PPH steam ÷ 36 PPH/kW = kW/hr

Turbine Exhaust @15 PSI - PPH steam ÷ 44.4 PPH/kW = kW/hr

## REFRACTORY

Typical 600 BHP unit requires 58,000 lbs. of HBC 3,000°F Mud. Ignition arch (for >35% M.C., wet basis fuels) requires 140 bags (50 lbs ea.) of 2,800°F castable.

**DISCLAIMER: These calculations are for estimating only. Always use best engineering practices.**

Provided by Gene Zebley, Energy System Sales

Hurst Boiler and Welding Co., Inc.

100 Boilermaker Lane

Coolidge, GA, 31768

Phone: (229) 346-3972

Fax: (229) 346-3874

Email: [boilrmkr@surfsouth.com](mailto:boilrmkr@surfsouth.com) / [gzebley@hurstboiler.com](mailto:gzebley@hurstboiler.com)

Web Site: [www.hurstboiler.com](http://www.hurstboiler.com)

